



- GENERAL NOTES:**
- BRICK PAVING SHALL BE HERRINGBONE PATTERN. BRICKS USED SHALL BE HARD FIRED WITH A NON-SLIP FINISH. BRICKS USED SHALL HAVE A WIDTH THAT IS HALF OF ITS LENGTH AND LAYED WITH MATCHED JOINTS.
 - ALL CONCRETE SURFACES SHALL BE 5" THICK AND SHALL BE FINISHED WITH A NON-SLIP FINISH. FINISH SHALL BE HERRINGBONE PATTERN AS INDICATED ON DRAWING. EXPANSION JOINTS IN BRICK PAVING TO BE FULL DEPTH OF CONCRETE SLAB AND SETTING BED. TOP THICKNESS OF BRICK TO BE GAUGED WITH SILEXON FILLER TO MATCH COLOR OF BRICK AT EXPANSION JOINTS.
 - EXPANSION JOINTS IN CONCRETE PAVING TO BE 1" PHENOLATED STEEL/CLAY COMPOSITION STRIPS. TOP 1/2 OF JOINT TO BE GAUGED WITH SILEXON FILLER. LIGHT GRAY IN COLOR. EXPANSION JOINT TO BE DEPTH OF CONCRETE SLAB.
 - SIDEWALKS TO BE FINISHED WITH 1/4" THICKNESS UNLESS CURED EITHER OF THE ACCESSIBLE RAMP (TYPE A, OR B) SHOWN MAY BE USED. DEPENDANT ON EXISTING CONDITIONS. UTILITY AND OTHER RAMP AT THE CORNER. ALL HERRINGBONE PATTERNS SHOULD INCLUDE DETECTABLE WARNING AND BE CONSTRUCTED IN ACCORDANCE WITH THE LATEST ADA REQUIREMENTS.
 - DETECTABLE WARNING SHALL BE HARD FIRING CLAY BRICKS WITH PROTRUDED CORNER THAT SHALL CONTRAST IN COLOR WITH SURROUNDING AREA AS PER DDD STANDARD.
 - IF REPAIRS MUST BE MADE CONTRACTOR TO REMOVE CONCRETE WITHIN CONTROL JOINT LINES TO MAINTAIN THE PATTERNING ON THE WALK.
 - STONE PAVING (AS SHOWN ON STD18) SHALL BE LAYED IN CONVENTIONAL PAVING PATTERN. A MINIMUM OF THREE WIDTHS OF STONE, WARNING BY 4" IN WIDTH REQUIRED. NO STONES OF THE SAME WIDTH ALLOWED SIDE BY SIDE. STONE SHALL BE A MINIMUM OF 1" THICKNESS AND HAVE A NON-SLIP FINISH. WORKED JOINTS SHALL BE 1/2" TO 1/4" FLUSH WITH SURFACE.

CITY OF NEW ORLEANS
DEPARTMENT OF PUBLIC WORKS
ENGINEERING DIVISION

BRICK, STONE & CONCRETE
SIDEWALK & MISCELLANEOUS DETAILS
FOR CONSTRUCTION IN THE
DOWNTOWN DEVELOPMENT DISTRICT

STANDARD DRAWING No. **STD17**

DATE: 11/11/11
SCALE: 1/4"=1'-0"

PROJECT: DOWNTOWN DEVELOPMENT DISTRICT

DESIGNED BY: [Name]
CHECKED BY: [Name]
IN CHARGE: [Name]

